



**PIPE BEDDING DETAIL**

SCALE 1:10

**NOTES**

1. ALL TRENCHES UNDER KERB AND CHANNEL, DRIVEWAYS, FOOTPATHS AND ROAD PAVEMENT SHOULD BE BACKFILLED AS PER COUNCIL'S SPECIFICATION, SECTION 18
2. ALL 150 PIPES TO BE PVC (SH), 225 TO BE PVC (SH) OR RRJ R.C./FRC, PIPES > 300 TO 600 INCLUSIVE TO BE RRJ WITH COLLAR, R.C / F.C.R.
3. ALL R.C./ F.R.C. PIPES TO BE CLASS 2 UNLESS SPECIFIED DIFFERENTLY.
4. EASEMENT DRAINS TO BE LOCATED TO ENSURE 500mm MINIMUM FROM EDGE OF PIPE TO EDGE OF EASEMENT. REINSTATEMENT WORKS REFER TO NOTE 1.
5. IF TRENCH IS WITHIN 150mm OF KERB THEN TRENCH IS TO BE BACKFILLED WITH SELECT BACKFILL FROM SITE AS DIRECTED. FOR NEW WORKS OR REINSTATEMENT WORKS REFER TO NOTE 1.
6. MINIMUM PIPE REQUIREMENTS UNDER ROAD PAVEMENTS AND TAKING ROAD RUNOFF TO BE 300MM DIA. RRJ R.C.

**CITY OF CASEY**

PIPE LAYING DETAIL  
NOT UNDER ROAD PAVEMENT

MANAGER OF ENGINEERING &  
ENVIRONMENTAL SERVICES

LAST UPDATE 09.11.2012

AMENDMENTS: GENERAL UPGRADE

S-323

V2