



PROVIDE TEMPORARY MARKER RISER 300 ABOVE GROUND. TO BE CAPPED OFF BELOW GROUND AFTER HOUSE DRAIN IS CONNECTED

FALL OF LAND

600mm DESIRABLE MINIMUM COVER

END TO BE CAPPED IF PIPE NOT CONNECTED TO HOUSE DRAIN

NOTES

1. ALL JOINTS TO BE SOLVENT WELDED WITH APPROVED SOLVENT.
2. HOUSE DRAIN TO BE MARKED ON SIDE OF THE FOOTPATH WITH APPROVED STAMP.
3. END OF HOUSEDRAIN TO BE EXTENDED 500mm INTO PROPERTY AND TAPED OR CAPPED.
4. HOUSE DRAIN TO BE INSTALLED 5.0m FROM LOW SIDE OF BLOCK UNLESS SERVICES INTERFERE.
5. IN SITUATIONS WHERE THERE IS NO FOOTPATH, A PEG IS TO BE INSTALLED AT END OF HOUSEDRAIN.
6. HAUNCHING OF PIPE REQUIRED IF TRENCH INFERIOR.
7. WHERE PIPE NOT INSTALLED IN SINGLE LENGTH, APPROVED CONNECTORS MUST BE USED.
8. ALL UPVC PIPES AND FITTINGS TO BE SEWER GRADE HEAVY – AS 1260
9. USE SIMILAR DETAIL FOR CONNECTION TO STORMWATER DRAINAGE PIT

CITY OF CASEY

PROPERTY DRAIN CONNECTION
TO STORMWATER DRAIN IN ROAD RESERVE

MANAGER OF ENGINEERING & ENVIRONMENTAL SERVICES
LAST UPDATE 09.11.2012

S-607 V2

AMENDMENTS: GENERAL UPGRADE, LOCATING RISER ADDED